

# Monthly Operating Report



May:2024



So. Sangamon  
Water Commission  
June 17<sup>th</sup>, 2024

# SSWC

9199 Buckhart Rd Rochester IL 62563

## TABLE OF CONTENTS

<b>SECTION</b>	<b>PAGE NO.</b>
<b>Executive Summary.....</b>	<b>ES-1</b>
<b>1. SAFETY .....</b>	<b>1-1</b>
1.1 Safety Training .....	1-1
1.2 Lost time Accidents .....	1-1
1.3 Safety Audit .....	1-1
1.4 Miscellaneous Safety.....	1-1
<b>2. COMPLIANCE, FLOWS AND LOADINGS .....</b>	<b>2-2</b>
2.1 Compliance .....	2-2
2.2 Influent flows and loadings .....	2-2
2.3 Effluent Concentrations .....	2-2
2.4 Lagoon Discharge Concentrations .....	2-4
<b>3. OPERATIONS.....</b>	<b>3-1</b>
3.1 Events impacting operations .....	3-1
3.2 Emergency & Service calls.....	3-1
3.3 Emergency Call-outs .....	3-1
3.4 Customer Inquiries .....	3-1
<b>4. MAINTENANCE AND REPAIR.....</b>	<b>4-8</b>
4.1 Preventative and predictive maintenance.....	4-8
4.2 Corrective repairs .....	4-8
<b>5. PROJECT MANAGEMENT &amp; SUPPORT.....</b>	<b>5-1</b>
5.1 Staffing & Training .....	5-1
5.2 Corporate Support.....	5.2
5.3 Budget .....	5-3
<b>6. CAPITAL PLANNING .....</b>	<b>6-1</b>
6.1 Approved CIP Projects Current status.....	6-1
6.2 Draft Capital Improvement Plan .....	6-1



## LIST OF TABLES

<b>TABLE</b>	<b>PAGE NO.</b>
Table 2.2 Influent Concentrations and Flow.....	2-2
Table 2.3 Finished Water Quality.....	2-2
Table 2.4 Weekly Grab Sample Analysis Results.....	2-4
Table 4.1 Budget Table.....	5-3

## EXECUTIVE SUMMARY

**Safety.** Safety is the number one priority at South Sangamon. We have instituted a monthly safety meeting for operations staff at the plant. There were no lost time accidents in the month of May 2024.

**Compliance.** The finished water quality was within regulatory limits and all reporting and sampling requirements were met for the month. A copy of the Operations Report submitted to the Illinois Environmental Protection Agency is available at [www.sswc.us](http://www.sswc.us)

During the month of May 2024, the plant pumped 39.339 million gallons from the well field and 32.082 million gallons of finished water. This is 7.1 million gallons less than May 2023.

The SSWC plant has been removed from Critical Review status.

**Operations.** There was 0 emergency call-outs for the month. There were numerous customer inquiry for the month.

**Maintenance and Repair.** For the month of May 2024, there were 31 inspections, 3 preventative and multiple corrective maintenance activity completed. There was 2 repair activities performed .

**Budget.** Passed at April 17<sup>th</sup> 2023 meeting.

### Capital Planning.

Chatham emergency interconnect

Onsite fuel storage tanks

Detention Tank

Well#11

# **1. SAFETY**

## **1.1 SAFETY TRAINING**

At South Sangamon we strive to provide a safe working environment for all employees. This is accomplished with daily safety meetings and open communication.

## **1.2 LOST TIME ACCIDENTS**

There were 0 lost time accidents in the month of May 2024.

## **1.3 SAFETY AUDIT**

No safety audits to date.

## **1.4 MISCELLANEOUS SAFETY**

No notable safety issues

## 2. COMPLIANCE, FLOWS AND LOADINGS

### 2.1 COMPLIANCE

The finished water quality was within regulatory limits and all Bacteriological testing was completed for the month of May. A copy of the Operations Report to the Illinois Environmental Protection Agency (IEPA) is available on the SSWC website.

### 2.2 INFLUENT FLOWS AND LOADINGS

The total gallons pumped from the well field were 47.485 MG. The influent parameters were all within the normal range.

The influent flow and loadings are summarized below in Table 2.2

**Table 2.2 Influent Concentrations and Flow**

	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Well Flow Gals (MGD)
<b>Max.</b>	7.5	15.7	5.63	.286	-	365	316	1.893
<b>Min.</b>	6.7	14.0	.36	.130	-	335	280	1.269
<b>Avg.</b>	6.95	14.5	1.09	.176	-	356	299	1.532
<b>Total</b>	-	-	-	-	-	-	-	47.485

### 2.3 EFFLUENT CONCENTRATIONS

The facility filtered 41.767 MG during the month with a daily average of 1.347 MG and a min/max 1.118/ 1.681 MG.

**Table 2.3 Finished Water Quality**

	Free CL2	Total CL2	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Phosphate
<b>Max.</b>	0.16	4.08	7.7		0.03	0.044	.97	300	316	1.85
<b>Min.</b>	0.05	3.31	7.0		0.01	0.001	0.40	100	280	1.34
<b>Avg.</b>	0.10	3.65	7.4		0.02	0.020	0.73	112	301	1.64
<b>MCL</b>	-	-	-	-	1.00	-	4.00	-	-	-
<b>SMCL</b>	-	-	-	-	0.30	0.050	2.00	-	-	-

## Finished Water Flow Comparison for FY 2023-24

Time Period	23-24	22-23	21-22
June 2023- May 2024	400,228,612	430,581,523	421,132,861
Increase for the same period last year	-30.353 MG	9.45 MG	

FINISHED WATER PUMPING HISTORY						
	2023-24	2022-23	2021-22	2020-21	2019-20	2018-19
June	22,455,176	38,496,145	37,616,256	17,414,377	33,460,303	34,040,000
July	41,565,811	38,861,790	39,001,640	44,237,066	23,742,374	41,178,722
Aug	39,770,720	36,977,913	39,953,900	39,638,063	25,018,633	35,176,238
Sept	38,677,420	32,355,302	38,935,839	38,674,095	34,234,782	34,754,000
Oct	32,733,224	29,576,287	34,918,955	34,597,739	30,769,238	30,353,482
Nov	30,061,570	35,563,717	31,181,005	32,325,040	30,877,400	30,464,000
Dec	31,818,986	30,450,255	31,391,459	31,582,311	29,703,954	31,930,000
Jan	33,807,516	37,721,005	32,322,270	31,456,987	30,073,516	28,823,375
Feb	29,777,768	33,481,076	32,451,653	30,638,842	28,797,693	28,625,431
Mar	31,222,925	36,781,261	33,909,417	33,633,244	30,339,298	31,237,000
Apr	31,707,537	36,832,617	31,991,050	33,214,211	31,542,650	28,418,249
May	36,629,959	43,484,155	37,459,417	35,932,776	34,673,848	33,045,927
	-----	-----	-----	-----	-----	-----
Totals	400,228,612	430,581,523	421,132,861	403,344,751	363,233,689	388,046,424
Avg	1.09 MGD	1.18 MGD	1.15 MGD	1.11 MGD	.992 MGD	1.06 MGD

## 2.4 LAGOON DISCHARGE CONCENTRATIONS

The results for the NPDES lagoon discharge permit are summarized below.

**Table 2.4 Weekly Grab Sample Analysis Results**

Lagoon Effluent Results						
Date	Fe (mg/l)	Mn (mg/l)	Chloride (mg/l)	Cl <sup>2</sup> (mg/l)	pH (S.U.)	TSS (mg/l)
May 14th, 2024						
Minimum	.04	.036	402.6	.01	7.6	6.4
Maximum	.04	.036	402.6	.01	7.6	6.4
Average	.04	.036	402.6	.01	7.6	6.4
<b>Monthly Avg Limit</b>	<b>2.000</b>	<b>1.000</b>				<b>15</b>
<b>Daily Limit</b>	<b>4.000</b>	<b>2.000</b>	<b>500</b>	<b>0.05</b>	<b>6.0-9.0</b>	<b>30</b>

The Chloride sample for the month, performed by the Springfield Metropolitan Sanitary District, was below 30,000 mg/l for the month of May 2024. The limit for chloride discharge to the sanitary district is 30,000 mg/L.

## **3. OPERATIONS**

### **3.1 EVENTS IMPACTING OPERATIONS**

**There were over 50 incident that impacted the operation of the plant.**

Ion exchange alarm

Westech filters comm loss

Power surge

Power Sag

Power Outages

Ion Exchange Brine Pump

Well Comm loss

Train #3 repair

### **3.2 EMERGENCY & SERVICE CALLS**

#### **Service Calls:**

- There was 0 emergency call out for the month.

### **3.3 EMERGENCY CALL-OUTS**

There was 0 emergency call out for the month.

### **3.4 CUSTOMER INQUIRIES**

There were numerous customer inquiries.

#### **OTHER WORK PERFORMED**

Inspected distribution mains

Inspected booster station

Customer service

Air Compressor Mounting Platform

SCADA programming

Mower Maintenance

New scada computers

Interconnect Start Up

Well Transducer installation

Well #3 excavating


Train #3 Repair



Justin King requested a 1.5" be installed. Newly installed meter



Brotke pulling well 5 to install the new transducer



Train #3 began leaking at the inlet side groovelock



After inspection it appears the manifold itself has a fine crack where the groove lock sits. The groove lock was removed and a repair coupler was put on in its place.



SSWC, Petersburg Plumbing, scadaWARE and Benton and Associates attempted the start up procedure for the new interconnect. As this was the first time putting power to the system Dan from scadaWARE had debugging to perform. Synergy Electric was also on site to assist with the electrical portion of the debugging



## **4. MAINTENANCE AND REPAIR**

### **4.1 PREVENTATIVE AND PREDICTIVE MAINTENANCE**

For the month of May 2024, there were 31 inspections, 3 preventative and multiple corrective maintenance activities completed.

### **4.2 CORRECTIVE REPAIR AND MAINTENANCE**

Pulling and cleaning pre filters on all 3 filter trains on weekly basis

CIP train 1,2 and 3

Purged air control system

Air Compressor service

Raw water line flushing

Detention tank flush

Flushing Air Lines

Maintenance of New Berlin Booster Station

Meter Transmitter Replacement

Air compressor Maintenance

Pneumatic Tank Maintenance

Train #3 Repair

Transducer Install



## **5. PROJECT MANAGEMENT & SUPPORT**

### **5.1 STAFFING & TRAINING**

- Staff member training has been continuous and ongoing.
- Operator and Asst. Operator have been studying for EPA licensing test.

### **5.2 OPERATIONAL SUPPORT**

The following individuals, either on-site or remotely, provided assistance in operation and/or maintenance of the plant during the month of May 2024.

- Kevin Canham
- Stephen Bivin
- Katie Krall
- Dan (SCADAware)
- Joe Lee Electric
- Kevin Garmin (SCADAware)



### **5.3 BUDGET**

Table 5.3 Operating Budget

**Table 5.3 Budget Table**

Budget Table was removed: see clerks report

## **6. CAPITAL PLANNING**

### **6.1 APPROVED CIP PROJECTS CURRENT STATUS**

Pigging project construction complete. Awaiting first pigging before completely releasing contractor.

The Chatham /South Sangamon emergency interconnect construction is mostly complete. The valve has arrived and has been installed. Multiple startups have been attempted. Due to various issues start up has not been completed. A new startup date is being planned.

Meter Project progressing, All meter bases and registers are on site. 31 cell meters have been installed.

Meco Engineering has provided us with initial plans for well #11. Well #11 construction permit has been approved and has been received at the plant. Flood Plain Permit has been received and is posted. MECO Engineering has been on site and sample wells have been drilled.

### **6.2 DRAFT CAPITAL IMPROVEMENT PLAN**

The CIP is a planning document that includes all projects anticipated to exceed \$5,000 in cost over the next five years. The CIP is an ongoing process and will be refined from time to time as projects are completed and new issues are identified.

1. Onsite fuel storage tanks have arrived on site and pumps have been installed-completed
2. BOP CPU upgrade has been completed
3. Second raw water detention tank
4. SSWC/Chatham interconnect
5. Well #11









